

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7259-0067:163 Page 1 of 1

**CATEGORY:** Air Sampling Smoke Detector

**LISTEE:** Siemens Building Technologies Inc., \*Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932  
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

**DESIGN:** ASSD ANALASER (High Sensitivity Smoke Detection Air Sampling Smoke Detection) System.

System components:

Air Sampling Network	
Detector Assembly	500-692895, -885, -886, 887
ACC Display Control Card	500-692905
Power Supply	500-692894
2 or 4 12V/33AH Batteries	500-693238
Zone Control (Multizone Enclosure)	599-692914, -915, -916, -917
Zone Control (Single Zone Enclosure)	599-692918

Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The sampling points should be installed at a location where they will receive the products of combustion produced by a fire anywhere in the protected area. Consideration should be given to such features as normal ventilation and air conditioning which would affect the sensitivity.

**MARKING:** Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

**APPROVAL:** Listed as an air sampling smoke detector system for use with any separately listed compatible control unit. Also suitable for open area protection with a maximum air transport time of no more than 60 seconds. Local authority having jurisdiction should be consulted prior to installation.

**XLF:** 7259-1076:108

\*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **OCTOBER 26, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager